

APM HEXSEAL®

44 Honeck Street
Englewood, NJ 07631
TEL: (201)569-5700
FAX: (201)569-4106
www.apmhexasal.com



General – The devices covered by this Report are intended for use with devices such as switches, circuit breakers, pilot lights etc. installed in an environmental rated enclosure and used with these devices to maintain the enclosure rating.

Ratings:

Product Type	Ratings
Full Toggle Switch Boots	Type 1, 2, 3, 4, 4X, 5, 6, 6P, 12, 12K, 13
Half Toggle Switch Boots	Type 1, 2, 3, 4, 4X, 5, 6, 6P, 12, 12K, 13
Full Pushbutton Switch Boots	Type 1, 2, 3, 4, 4X, 5, 6, 6P, 12, 12K, 13
Half Pushbutton Switch Boots	Type 1, 2, 3, 4, 4X, 5, 6, 6P, 12, 12K, 13
Rotary Shaft Seals	Type 1, 2, 3, 4, 4X, 5, 6, 6P, 12, 12K, 13
Circuit Breaker Boots frame mounted	Type 1, 2, 3, 4, 4X, 5, 6P, 12, 12K
Circuit Breaker Boots HE10XX, C1113, 1113/2,-3,-4,-14,-15,-40,-43	Type 1, 2, 3, 3R, 3S, 4, 4X, 5, 6, 12, 12K
Rocker Switch Boots	Type 1, 2, 3R, 5, 12, 12K, 13
Indicator and Illuminated Switch Seals	Type 1, 2, 3, 4, 4X, 5, 6, 6P, 12, 12K, 13
Self-Sealing Fasteners	Type 1, 2, 3, 4, 4X, 5, 6, 6P, 12, 12K, 13
Self-Sealing Bolts and Locking Nuts	Type 1, 2, 3, 4, 4X, 5, 6, 6P, 12, 12K, 13
Panel Bushing Seal for sealed switches/circuit breakers	Type 1, 2, 3, 4, 4X, 5, 6, 12, 12K
Seeloc Washers	Type 1, 2, 3, 4, 4X, 5, 6, 12, 12K

Material – The following silicone rubber may be used in the construction of the devices covered in this report.

1. Rhodorsil Type RS1925
2. General Electric SE6660
3. General Electric SE6635 Blend
4. Wacker Silicone SWS 7172

Engineering Considerations (Not for UL Representative use):

CNR – Indicates investigation to Canadian National Standards C22.2 No. 40.

1. The seals have been investigated as to maintain the integrity of an enclosure when installed per manufacturer's instructions
2. Seals were test mounted on stainless steel plates
3. Circuit breaker seals for panel mounting were tested for types 1, 2, 3, 3R, 3S, 4, 4X, 5, 6, 6P, 12, 12K and 13 with acceptable results. The circuit breaker seals were designed for specific breakers.

File: E153680

Volume: 1

Section: 1 and report

Page: 4

Issued: 1994-05-19

Revised: 2006-06-23